

LOCATION 801 + 807 E Garrison Blvd

CITY GASTONIA

BETWEEN Church

STREET & Chestnut

STREET

	SIZE	801 TYPE 807		801 LENGTH 807		INSTALLED	801 RETIRED 807		RENEWED
MAIN TO BLDG.	3/4"	P	P	213'	68'	12-18-97	12-18-97	12-18-97	
MAIN TO PROP. LINE	3/4	P	P	10'	2'		30'	210'	
PROP. LINE TO BLDG	3/4	P	P	203'	66'		P 6ris	3/4" CW	

ENTERS: 801 BRANCHED INTO: 807 1983 1968

TAP SIZE: 3/4 PRESSURE 60# PSI INCHES W.C. LOCATION 15' E OF Chestnut


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS BY M. Parker

MAIN-SIZE 2" C.I. BARE STEEL COATED STEEL PLASTIC ☒ YEAR INSTALLED 1997

DEPTH 3 FT 0 IN. LOCATION South of E Garrison Blvd.

"A" P/S READING P TOTAL ANODES 1# 17# L.R. #

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	P Riser
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY