

LOCATION 824 Garrison Blvd CITY Cosmos
BETWEEN Church STREET & Chestnut STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED <input checked="" type="checkbox"/>	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>167'</u>			<u>8-2-97</u>
MAIN TO PROP. LINE	<u>1 1/2</u>	<u>"</u>	<u>78'</u>			
PROP. LINE TO BLDG.	<u>1 1/2</u>	<u>"</u>	<u>89</u>			

ENTERS: 824 BRANCHED INTO: 90.2

TAP SIZE: 1/2 PRESSURE _____ PSI _____ INCHES W.C. LOCATION 38' S. of C of Garrison


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY GP

MAIN-SIZE 10" C.I. _____ BARE STEEL _____ COATED STEEL ☒ PLASTIC _____ YEAR INSTALLED 1967

DEPTH: 4 FT 0 IN. LOCATION _____

"A" P/S READING 1.20 TOTAL ANODES 1# _____ 17# _____ L.R. # _____

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>SR</u>	<u>P</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY