

LOCATION 929 E. Garrison Blvd. Ste #5CITY GastoniaBETWEEN South ChurchSTREET & Reid

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4	Pla	10'		11-12-97	
MAIN TO PROP. LINE	3/4	Pla	2'			
PROP. LINE TO BLDG.	3/4	Pla	12'			


ENTERS: Same

BRANCHED INTO:

TAP SIZE: 3/4 PRESSURE 60 PSI _____ INCHES W.C. LOCATION 238 Ft. E. of S churchPRESSURE TEST @ 100 PSI FOR 1/4 HRS BY James DaytonMAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC X YEAR INSTALLED 1997DEPTH: 3 FT 0 IN. LOCATION 109 Ft. N. of E. 8th Ave."A" P/S READING PLA. TOTAL ANODES 1# _____ 17# _____ L.R. # _____

REMARKS:

Total pipe 10'
Total BORE 0



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY