

LOCATION 929 E. GARRISON Blvd. Ste #18CITY GastoniaBETWEEN S. ChurchSTREET & Reid

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>Pla</u>	<u>12'</u>		<u>11-12-97</u>	
MAIN TO PROP. LINE	<u>3/4</u>	<u>Pla</u>	<u>3'</u>			
PROP. LINE TO BLDG.	<u>3/4</u>	<u>Pla</u>	<u>15'</u>			


ENTERS: Same

BRANCHED INTO:

TAP SIZE: 3/4 PRESSURE 60 PSI \_\_\_\_\_ INCHES W C LOCATION 170' E of S. ChurchPRESSURE TEST: @ 100 PSI FOR 1/4 HRS BY James DeytonMAIN-SIZE 2" C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL \_\_\_\_\_ PLASTIC X YEAR INSTALLED 1997DEPTH. 3 FT. 0 IN. LOCATION 109' N of E 8th Ave."A" P/S READING Pla. TOTAL ANODES 1# \_\_\_\_\_ 17# \_\_\_\_\_ L.R. # \_\_\_\_\_

REMARKS:

total pipe 12'  
Total Bore 0



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY