

LOCATION 1020 GARRISON BLVD CITY Gastonia
BETWEEN Reid St. STREET & Dogwood STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>96'</u>		<u>X</u>	<u>7-12-91</u>
MAIN TO PROP. LINE	<u>1"</u>	<u>1"</u>	<u>75'</u>			
PROP. LINE TO BLDG.	<u>1"</u>	<u>1"</u>	<u>21'</u>			

ENTERS: 1020 BRANCHED INTO: -


TAP SIZE: 1/2 PRESSURE _____ PSI _____ INCHES W.C. LOCATION 34' S. of Cor
Garrison Blvd

PRESSURE TEST. @ 100 PSI FOR 1/4 HRS. BY GP
MAIN-SIZE 10" C.I. _____ BARE STEEL _____ COATED STEEL ✓ PLASTIC _____ YEAR INSTALLED 1969

DEPTH: 2 FT. 6 IN LOCATION _____

"A" P/S READING 1.40 TOTAL ANODES 1# 17 # _____ L.R. # _____

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>ER</u>	<u>P</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY