

LOCATION 1111 E. CARLISON Blvd. CITY Cassopolis
BETWEEN Laurel Lane STREET & Dogwood Dr. STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>76'</u>			<u>7-26-97</u>
MAIN TO PROP. LINE	<u>3/4"</u>	<u>P</u>	<u>5'</u>			
PROP. LINE TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>71'</u>			

ENTERS: 1111 BRANCHED INTO:
TAP SIZE: 1/2 PRESSURE 60 PSI INCHES W.C. LOCATION 209' E. of center of
Dogwood Dr

PRESSURE TEST: @ 100 PSI FOR 1/4 HRS BY S. Huffstiller
MAIN-SIZE 10' C.I. BARE STEEL COATED STEEL ✓ PLASTIC YEAR INSTALLED
DEPTH: 4 FT. 0 IN LOCATION 35' S. of center of E. CARLISON Blvd.

P/S READING 1.8 TOTAL ANODES 1# 0 17# 0 L.R. #

RKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY