

LOCATION 1315 E. GARRISON Blvd. CITY GAstonia
BETWEEN Carlton STREET & Peachtree STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>Plastic</u>	<u>75'</u>	<u>7-26-97</u>	<u>100' 3/4</u>	<u>Bare to be</u>
MAIN TO PROP. LINE	<u>3/4</u>	<u>Plastic</u>	<u>5'</u>		<u>Retired</u>	<u>with main</u>
PROP. LINE TO BLDG	<u>3/4</u>	<u>Plastic</u>	<u>10'</u>			

ENTERS: 1315 BRANCHED INTO: 0
TAP SIZE: 3/8 PRESSURE 60 PSI _____ INCHES W.C. LOCATION 228' w of C of Carlton Dr.

PRESSURE TEST. @ 100 PSI FOR 1/4 HRS BY RL
MAIN-SIZE 10" C.I. _____ BARE STEEL _____ COATED STEEL ✓ PLASTIC _____ YEAR INSTALLED 1980
DEPTH 3 FT. 6 IN. LOCATION 38' S of C of E-GARRISON Blvd.

"A" P/S READING 1-2 TOTAL ANODES 1# 0 17# 0 L.R. # 450998

REMARKS:

	Test Station			ENG. DEPT. USE ONLY
	Reading & Location	Lead	Volts	
	P/S Pipeline Lead - Red New Service	<u>S</u>	<u>Riser</u>	
	P/S Pipeline Lead - White Existing Main	<u>E</u>	<u>Plastic</u>	