


LOCATION 1324 Garrison Blvd.CITY CASTONIABETWEEN Carlton Dr.STREET & Laurel Lane

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P.</u>	<u>40'</u>	<u>5-21-94</u>	<u>Tied over 58' Existing</u>	
MAIN TO PROP. LINE					<u>3/4 Plastic</u>	
PROP. LINE TO BLDG.						

ENTERS: 1324BRANCHED INTO: 0TAP SIZE: 1/2PRESSURE 60 P.S.I. _____ INCHES W.C.LOCATION 134' N of Co of Garrison Blvd.PRESSURE TEST: @ 100 psi For 1/4 Hrs. By RLMAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 1993DEPTH: 3 Ft. 0 In. LOCATION 19' W of Co of Carlton Dr."A" P/S READING P TOTAL ANODES 1* _____ 17* _____ L.R. # _____

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>P</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY