

LOCATION 1424 E. Garrison Blvd. CITY BASTONIA
BETWEEN Church Hill Dr. STREET & Carlton Dr. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>Plastic</u>	<u>35'</u>	<u>3-20-96</u>		
MAIN TO PROP. LINE	<u>3/4</u>	<u>Plastic</u>	<u>14'</u>			
PROP. LINE TO BLDG.	<u>3/4</u>	<u>Plastic</u>	<u>21'</u>			

ENTERS: 1432 E. Garrison Blvd. BRANCHED INTO: 1424 E. Garrison Blvd.
TAP SIZE: 3/8" PRESSURE 60 PSI _____ INCHES W.C. LOCATION 370' E of C of Carlton Dr.


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY RL

SERVICE MAIN SIZE 3/4 C.I. _____ BARE STEEL _____ COATED STEEL ☒ PLASTIC _____ YEAR INSTALLED 11-22-1965

DEPTH. 2 FT 0 IN. LOCATION 110' N of C of E. Garrison Blvd.

"A" P/S READING .50 TOTAL ANODES 1# 1 17# _____ L.R. # 131215

REMARKS.



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>Riser Plastic</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY