

LOCATION 1432 E Garrison Blvd

CITY Gastonia

BETWEEN Churchill STREET &amp; Carlton STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4	P	230'	11-22-65	2-12-97	7-17-97
MAIN TO PROP. LINE	3/4	P	77'		RETIRED 193'	Tied over
PROP. LINE TO BLDG.	3/4	P	153'		3/4" CTW	3/4" P

ENTERS: 1432

BRANCHED INTO: -

TAP SIZE: 3/8

PRESSURE 60 PSI

INCHES W.C

LOCATION 338' W OF

Churchill

PRESSURE TEST: @ 100 PSI FOR 1/4 HRS BY M Parker

MAIN-SIZE 10" C.I. BARE STEEL COATED STEEL ☒ PLASTIC YEAR INSTALLED 1969


DEPTH: 3 FT 0 IN. LOCATION 37' south of Garrison

"A" P/S READING 1.2

TOTAL ANODES 1# 17#

L.R. #

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	P risea
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY