

LOCATION 1844 E Garrison Blv. CITY GASTONIA
BETWEEN OWENS DR. STREET & TORRENCE DR. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>PIA.</u>	<u>64 Ft.</u>		<u>10-8-97</u>	
MAIN TO PROP. LINE	<u>3/4</u>	<u>PIA.</u>	<u>40 Ft.</u>			
PROP. LINE TO BLDG.	<u>3/4</u>	<u>PIA.</u>	<u>24 Ft.</u>			


ENTERS: SAME BRANCHED INTO _____
TAP SIZE: 3/4 PRESSURE 60 PSI _____ INCHES W C LOCATION EAST of 1844 Garrison

PRESSURE TEST: @ 100 PSI FOR 1/4 HRS BY JAMES DEYTON
MAIN-SIZE 2 C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC X YEAR INSTALLED 1997
DEPTH: 3 FT 2 IN LOCATION 19' East of Owens Dr

"A" P/S READING PIA. TOTAL ANODES 1# _____ 17# _____ L.R. # _____

REMARKS:

Total Pipe = 64 Ft.
Total Bore = 43 Ft.



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY