

LOCATION 1912 & 1904 E. Garrison Blvd. CITY GASTONIA
BETWEEN New Hope STREET & Owens Dr. STREET


	SIZE	TYPE	1912 LENGTH	1904	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>Plastic</u>	<u>170'</u>	<u>55'</u>	<u>7-19-97</u>	<u>Tied over 45'</u>	<u>Existing 3/4 Plastic</u>
MAIN TO PROP. LINE	<u>3/4</u>	<u>Plastic</u>	<u>80'</u>	<u>30'</u>		<u>160' Existing 3/4 G.W. To Be Retired</u>	
PROP. LINE TO BLDG.	<u>3/4</u>	<u>Plastic</u>	<u>90'</u>	<u>25'</u>		<u>with Main - 30' OF Plastic Also.</u>	

ENTERS: 1912 BRANCHED INTO: 1904
TAP SIZE: 3/8 ^{ON 1912} _{3/4 Tee on 1904} PRESSURE 60 PSI _____ INCHES W.C. LOCATION _____

PRESSURE TEST: @ 100 PSI FOR 1/4 HRS BY RL
MAIN-SIZE 10" C.I. _____ BARE STEEL _____ COATED STEEL ✓ PLASTIC _____ YEAR INSTALLED 1989
DEPTH: 3 FT. 0 IN LOCATION _____

"A" P/S READING _____ TOTAL ANODES 1# 0 17# 0 L.R. # 447222

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>Riser's</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	<u>Plastic</u>

ENG. DEPT. USE ONLY