

LOCATION 245 W. Garrison Blvd. CITY GASTONIA

BETWEEN Gibbons St STREET & Nell St STREET

|                     | SIZE | TYPE | LENGTH | INSTALLED | RETIRED | RENEWED |
|---------------------|------|------|--------|-----------|---------|---------|
| MAIN TO BLDG.       | 3/4" | P    | 253'   | 6-20-96   |         |         |
| MAIN TO PROP. LINE  | 3/4" | P    | 155'   |           |         |         |
| PROP. LINE TO BLDG. | 3/4" | P    | 98'    |           |         |         |

ENTERS: 245 BRANCHED INTO:

TAP SIZE: 1/2 PRESSURE 60 PSI          INCHES W.C. LOCATION 12' N. of center of

Gibbons St.


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY S. Huffstutter

MAIN-SIZE 1" C.I.          BARE STEEL ✓ COATED STEEL          PLASTIC          YEAR INSTALLED P-30

DEPTH: 2 FT. 0 IN. LOCATION 21' N. of center of Eighth St.

"A" P/S READING .1 TOTAL ANODES 1# 1 17# 0 L.R. # 325205

REMARKS:



| Test Station                               |          |       |
|--|----------|-------|
| Reading & Location                         | Lead     | Volts |
| P/S Pipeline Lead - Red<br>New Service     | <b>S</b> |       |
| P/S Pipeline Lead - White<br>Existing Main | <b>E</b> |       |

ENG. DEPT. USE ONLY