

LOCATION 501 W. GARRISON Blvd CITY GASTONIA

BETWEEN S Chester ST. STREET & Jackson ST. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>ctw</u>	<u>3'</u>	<u>12-17-94</u>	<u>TIE ^{OVER} over</u>	<u>68'</u>
MAIN TO PROP. LINE					<u>of ctw</u>	
PROP. LINE TO BLDG.					<u>Source</u>	

ENTERS: 501 BRANCHED INTO:

TAP SIZE: 1/2 PRESSURE 60 P.S.I. _____ INCHES W.C. LOCATION 126' W. of center of S. Chester St

PRESSURE TEST: @ 100 psi For 1/4 Hrs. By S. HURST

MAIN-SIZE 10" C.I. _____ BARE STEEL _____ COATED STEEL ☒ PLASTIC _____ YEAR INSTALLED 1969

DEPTH: 3 Ft. In. LOCATION 38' S. of center of W. GARRISON Blvd.


"A" P/S READING 1.5 TOTAL ANODES 1* 0 17* 0 L.R. # _____

REMARKS: TIED over to 10" ctw main JERRY,

INSULATOR WAS REMOVED PER JERRY WARREN WAS INSULATOR

THIS ONE WAS REMOVED WHEN

TIED OVER it WAS



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	1.5 Riser
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY