


LOCATION 515 W. Garrison Blvd.CITY GASTONIABETWEEN JACKSON ST.STREET & Chester St.

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>CHW</u>	<u>2'</u>	<u>12-17-94</u>	<u>Tied over 65' Existing $\frac{3}{4}$</u>	
MAIN TO PROP. LINE					<u>CHW Pipe</u>	
PROP. LINE TO BLDG.						

ENTERS: 515BRANCHED INTO: 0TAP SIZE: 3/8 PRESSURE 60 P.S.I. INCHES W.C. LOCATION 170' E of Cor Jackson St.PRESSURE TEST: @ 100 psi For 1/4 Hrs. By RLMAIN-SIZE 10" C.I. BARE STEEL COATED STEEL ✓ PLASTIC YEAR INSTALLED 1969DEPTH: 3 Ft. 0 In. LOCATION 40' S of Cor Garrison Blvd."A" P/S READING 1.6 TOTAL ANODES 1* 17* L.R. #

REMARKS:

Bare Main Renewal - Tie Over's

Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	Riser 1.6
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY