

LOCATION 711 W. GARRISON Blvd. CITY Boston MA
BETWEEN Clay St. STREET & Trenton STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>Plastic</u>	<u>18'</u>	<u>12-17-94</u>	<u>41' Existing</u>	<u>3/4 C/W</u>
MAIN TO PROP. LINE	<u>3/4</u>	<u>Plastic</u>	<u>5'</u>			
PROP. LINE TO BLDG.	<u>3/4</u>	<u>Plastic</u>	<u>13'</u>			

ENTERS: 711 BRANCHED INTO: 0

TAP SIZE: 3/8 PRESSURE 60 P.S.I. _____ INCHES W.C. LOCATION 143' W of E of Clay St.


PRESSURE TEST: @ 100 psi For 1/4 Hrs. By RL

MAIN-SIZE 10" C.I. _____ BARE STEEL _____ COATED STEEL ☒ PLASTIC _____ YEAR INSTALLED 1969

DEPTH: 3 Ft. 0 In. LOCATION 38' S of E of GARRISON Blvd.

"A" P/S READING 1.6 TOTAL ANODES 1# _____ 17# _____ L.R. # _____

REMARKS: Bare Main Renewal



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	Riser Plastic N/A
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY