

LOCATION 850 W- Garrison Blvd. CITY OASTONIA
BETWEEN PARAMONT STREET & Trenton St. STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>Plastic</u>	<u>75'</u>	<u>12-14-94</u>	<u>Tied over</u>	<u>175' Existing</u>
MAIN TO PROP. LINE					<u>3/4 Plastic</u>	
PROP. LINE TO BLDG.						

ENTERS: 850 BRANCHED INTO: 840
TAP SIZE: 3/8 PRESSURE 600 P.S.I. INCHES W.C. LOCATION 110' E of C of PARAMONT

PRESSURE TEST: @ 100 psi For 1/4 Hrs. By RL
MAIN-SIZE 10" C.I. BARE STEEL COATED STEEL ✓ PLASTIC YEAR INSTALLED 1964
DEPTH: 3 Ft. 0 In. LOCATION 30' S of C of GARRISON Blvd.

"A" P/S READING 1.40 TOTAL ANODES 1* 17* L.R. #

REMARKS: Bare Main Renewal Project - Tie over's.



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>Riser Plastic</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY