

LOCATION 908 W Garrison Blvd. CITY GASTONIA
BETWEEN PARAMOUNT STREET & S WELDON STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>CU</u>	<u>(108' EXIST)</u>	<u>4-15-1970</u>		
MAIN TO PROP. LINE			<u>2' NEW 3/4"</u>	<u>TIED OVER</u>		
PROP. LINE TO BLDG.			<u>CU</u> <u>110' TOTAL</u>	<u>(2-1-95)</u>		

ENTERS: 908 BRANCHED INTO:

TAP SIZE: 3/8 PRESSURE 60 P.S.I. _____ INCHES W.C. LOCATION 38' SOUTH OF

Garrison Blvd.


PRESSURE TEST: @ 100 psi For 1/4 Hrs. By M Parker

MAIN-SIZE 10" C.I. _____ BARE STEEL _____ COATED STEEL X PLASTIC _____ YEAR INSTALLED 1969

DEPTH: 3 Ft. 0 In. LOCATION 159' W OF PARAMOUNT circle

"A" P/S READING 1.3 TOTAL ANODES 1* 0 17* 0 L.R. # _____

REMARKS: SERVICE TIED IN solid (1.3) after tie in (.4 prior to)



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>CU RISE</u> <u>1.3</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY