

LOCATION 915 GARRISON & 821 7th st.

CITY GASTONIA

BETWEEN PARAMOUNT C.V.

STREET & WALDON

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4	P	30'	11-19-94	tidied over 171	' of 3/4 C/W
MAIN TO PROP. LINE					Sev. to Ext	10" C/W Main
PROP. LINE TO BLDG.						

ENTERS: 821 7th st.

BRANCHED INTO: 915 GARRISON

TAP SIZE: 1/2

PRESSURE

P.S.I.

INCHES W.C.

LOCATION 38' S. of C of
Garrison Blvd

PRESSURE TEST: @ 100 psi For 1/4 Hrs. By SP

MAIN-SIZE 10" C.I. — BARE STEEL — COATED STEEL ☒ PLASTIC — YEAR INSTALLED 1969

DEPTH: 5 Ft. 0 In.

LOCATION


"A" P/S READING TOTAL ANODES 1* 17* 1 L.R. #

REMARKS: tied wire off at main

JERRY, 7-6-96
I NEED A
READING FOR
THIS ONE.

Test Station

ENG. DEPT. USE ONLY



Reading & Location

Lead

Volts

P/S Pipeline Lead - Red
New Service

R

P/S Pipeline Lead - White
Existing Main

E