

LOCATION 915 GARRISON & 821 7th St.

CITY GASTON, A

BETWEEN PARAMOUNT C.N

STREET & Weldon

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	$\frac{3}{4}$	P	30'	11-19-94	tied over 171'	' of $\frac{3}{4}$ c/w
MAIN TO PROP. LINE					sev. to Ext	10" c/w main
PROP. LINE TO BLDG.						

ENTERS: 821 7th St.

BRANCHED INTO: 915 GARRISON

TAP SIZE: $\frac{1}{2}$

PRESSURE

P.S.I.

INCHES W.C.

LOCATION 38' S. of C of Garrison Blvd

PRESSURE TEST: @

100

psi

For

$\frac{1}{4}$

Hrs.

By

SP

MAIN-SIZE

10"

C.I.

BARE STEEL

COATED STEEL

PLASTIC

YEAR INSTALLED

1969

DEPTH:

5

Ft.

0

In.

LOCATION

"A" P/S READING

1.10

TOTAL ANODES

1*


17*

1

L.R. #

REMARKS:

tied wire off at main



Test Station

ENG. DEPT. USE ONLY

Reading & Location

Lead

Volts

P/S Pipeline Lead - Red
New Service

R

P/S Pipeline Lead - White
Existing Main

E