

LOCATION 1306 W Garrison Blvd CITY GASTONIA

BETWEEN VANCE ST STREET & EMERSON ST STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>Plastic</u>	<u>20'</u>			<u>12/3/94</u>
MAIN TO PROP. LINE	<u>3/4"</u>		<u>20'</u>			
PROP. LINE TO BLDG.	<u>3/4"</u>		<u>20'</u>			

ENTERS: 1306 BRANCHED INTO:

TAP SIZE: 1/2" PRESSURE 60 P.S.I. _____ INCHES W.C. LOCATION North side of 1306


PRESSURE TEST: @ 100 psi For 1/4 Hrs. By DT

MAIN-SIZE 3/4" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 1994

DEPTH: 1 Ft. 6 In. LOCATION North side of 1304

"A" P/S READING 0 TOTAL ANODES 1*0 17*0 L.R. # 510503

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY