

LOCATION 1519 W. GARRISON Blvd. CITY GASTONIA  
BETWEEN LINWOOD Rd. STREET & WEBB ST. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>Plast.</u>	<u>21'</u>	<u>12-16-94</u>		
MAIN TO PROP. LINE	<u>3/4</u>	<u>Plast.</u>	<u>5'</u>			
PROP. LINE TO BLDG.	<u>3/4</u>	<u>Plast.</u>	<u>16'</u>			

ENTERS: 1519 W. GARRISON Blvd. BRANCHED INTO: 0  
TAP SIZE: 3/8 PRESSURE 60 P.S.I. INCHES W.C. LOCATION 132' E of Cof Webb St.


PRESSURE TEST: @ 100 psi For 4 Hrs. By B.S.

MAIN-SIZE 10" C.I.      BARE STEEL      COATED STEEL ☒ PLASTIC      YEAR INSTALLED 1969

DEPTH: 3 Ft. 0 In. LOCATION 37' S of Cof GARRISON Blvd.

"A" P/S READING 1.6 TOTAL ANODES 1\*      17\*      L.R. # 005661617

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	Plastic Riser
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY