

LOCATION 1621 E GARRISON Blvd CITY Boston  
BETWEEN Burtonwood STREET & Churchill STREET


	SIZE	TYPE	LENGTH	RETIRED	RENEWED
MAIN TO BLDG.	2"	CW	352'	8/27/98	
MAIN TO PROP. LINE			20'		
PROP. LINE TO BLDG.			332'		

ENTERS: 1621 BRANCHED INTO:  
TAP SIZE: 2" PRESSURE 60 PSI \_\_\_\_\_ INCHES WC LOCATION EAST side of 1621

PRESSURE TEST @ 100 PSI FOR 3 HRS BY DT  
MAIN-SIZE 10" C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL ☒ PLASTIC \_\_\_\_\_ YEAR INSTALLED 1969  
DEPTH: 3 FT 0 IN LOCATION South side of Garrison Blvd

"A" P/S READING 1.40 TOTAL ANODES 1# 0 17# 0 L.R. # 2021004

REMARKS Tied over 352' of 2" CW service to 10" CW main  
Also tied over 213' of 3/4" Plastic service to Kitchen of Church  
Also tied over 503' of CW service to Girl Scout Hut of Church  
And tied over 562' of CW service to Boy Scout Hut of Church  
AIR tested 1065' of 3/4" CW Pipe, 213' of 3/4" Plastic Pipe and 352' of 2" CW Pipe  
for 3 hrs.



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY  
Note: The 1.40 PS Reading was taken from the 10" CW main.  
R, 1621 Church 1.10  
R Girl Scout Hut 1.30  
R Boy Scout Hut 1.10  
R Kitchen Plastic service