

LOCATION 1770 W. Garrison Blvd.CITY GASTONIABETWEEN Robinson St.STREET & Webb St.

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>Plastic</u>	<u>128'</u>	<u>11-19-94</u>	<u>Retired 70' Existing 3/4 (FW)</u>	
MAIN TO PROP. LINE	<u>3/4</u>	<u>Plastic</u>	<u>82'</u>		<u>Service Purged with Air &</u>	
PROP. LINE TO BLDG.	<u>3/4</u>	<u>Plastic</u>	<u>46'</u>		<u>Capped with Main</u>	


ENTERS: 1770BRANCHED INTO: 0TAP SIZE: 3/8PRESSURE 60

P.S.I.

INCHES W.C.

LOCATION 95' E of Co of Robinson St.PRESSURE TEST: @ 100 psi For 1/4 Hrs. By ALMAIN-SIZE 10" C.I. BARE STEEL COATED STEEL ✓ PLASTIC YEAR INSTALLED 1969DEPTH: 3 Ft. 0 In. LOCATION 36' S of Co of Garrison Blvd. under Sidewalk"A" P/S READING 60TOTAL ANODES 1# 17# 1L.R. #

REMARKS:

Bare Main Replacement
Program

Test Station

ENG. DEPT. USE ONLY

Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	Riser Plastic
P/S Pipeline Lead - White Existing Main	E	