

LOCATION 1206 Canton Ave CITY Carthage
BETWEEN N. Vance STREET & Firestone STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>9w</u>	<u>8'</u>			
MAIN TO PROP. LINE				<u>Relocated 2-16-86</u>		
PROP. LINE TO BLDG.						

ENTERS: 1206 BRANCHED INTO: 120

TAP SIZE: 3/4 PRESSURE 60 P.S.I. 1 1/2 INCHES W.C. LOCATION


PRESSURE TEST: @ 100 psi For 44 Hrs. By LP

MAIN-SIZE 3/4 C.I. BARE STEEL COATED STEEL / PLASTIC YEAR INSTALLED

DEPTH: 2 Ft. 6 In. LOCATION

"A" P/S READING 1.2 TOTAL ANODES 1* 0 17* 0 L.R. #

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u> <u>Riser</u>	<u>1.2</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY