

LOCATION 794 Gaston Day School Rd Bldg A CITY GASTONIA
BETWEEN Honeywood LN STREET & Union Rd STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4"	Plastic	142'	3/21/96		
MAIN TO PROP. LINE	3/4"		47'			
PROP. LINE TO BLDG.	3/4"		95'			

ENTERS: 794 BRANCHED INTO:

TAP SIZE: 3/8" PRESSURE 60 PSI INCHES W.C. LOCATION W side of 794


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY DT

MAIN-SIZE 6" C.I. BARE STEEL COATED STEEL PLASTIC YEAR INSTALLED 1965

DEPTH: 3 FT. 0 IN. LOCATION South side of Union Rd

"A" P/S READING 1.40 TOTAL ANODES 1# 0 17# 0 L.R. # 141450

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY