

LOCATION 900 GASTON DAY SCHOOL RD CITY GASTONIA
BETWEEN UNION RD STREET & WEYMOUTH DR. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>PLASTIC</u>	<u>67'</u>	<u>3-4-97</u>		
MAIN TO PROP. LINE	<u>3/4</u>	<u>PLASTIC</u>	<u>19'</u>			
PROP. LINE TO BLDG.	<u>3/4</u>	<u>PLASTIC</u>	<u>48'</u>			


ENTERS: 900 BRANCHED INTO: D
TAP SIZE: 3/8 PRESSURE 60 PSI 0 INCHES W.C. LOCATION 137' W OF COE
WEYMOUTH DR

PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY R L
MAIN-SIZE 4" C.I. BARE STEEL COATED STEEL PLASTIC YEAR INSTALLED 1969

DEPTH: 3' FT 0 IN LOCATION 13' N OF COE GASTON DAY SCHOOL RD

"A" P/S READING 1.5 TOTAL ANODES 1# 0 17# 0 L.R. # 0119870

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>PLASTIC</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	<u>Riser</u>

ENG. DEPT. USE ONLY