

LOCATION 1840 Gaston Day School Rd CITY GASTON, NC  
BETWEEN Hearthstone Dr STREET & Lincoln Ln STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>221'</u>	<u>9-5-97</u>		
MAIN TO PROP. LINE	<u>3/4"</u>	<u>P</u>	<u>50'</u>			
PROP. LINE TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>171'</u>			

ENTERS: 1840 BRANCHED INTO:  
TAP SIZE: 1/2 PRESSURE 60 PSI INCHES W.C. LOCATION 446' NE of center of  
Hearthstone Dr.

PRESSURE TEST: @ 100 PSI FOR 1/4 HRS BY S. HUFFSTETTER  
MAIN-SIZE 4" C.I.        BARE STEEL        COATED STEEL ✓ PLASTIC        YEAR INSTALLED 1979  
DEPTH: 3 FT 0 IN LOCATION 15' N. of center of Gaston Day School Rd.

"A" P/S READING 1.3 TOTAL ANODES 1# 0 17# 0 L.R. # 588444

REMARKS:

	Test Station			ENG. DEPT. USE ONLY
	Reading & Location	Lead	Volts	
	P/S Pipeline Lead - Red New Service	<b>S</b>		
	P/S Pipeline Lead - White Existing Main	<b>E</b>		