

LOCATION 1463 Gaston Day Sch Rd CITY GASTONIA

BETWEEN _____ STREET & _____ STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>5/6</u>	<u>P</u>	<u>97'</u>	<u>10-17-01</u>		
MAIN TO PROP LINE	<u>1"</u>	<u>1"</u>	<u>15'</u>			
PROP LINE TO BLDG	<u>1"</u>	<u>1"</u>	<u>82'</u>			

ENTERS 1463 BRANCHED INTO _____

TAP SIZE 3/4 PRESSURE 60 PSI _____ INCHES W C LOCATION W side house


PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY SM

MAIN-SIZE 6" C I _____ BARE STEEL _____ COATED STEEL / PLASTIC _____ YEAR INSTALLED _____

DEPTH 5 FT 6 IN LOCATION N. side of Gaston Day School

"A" P/S READING _____ TOTAL ANODES 1# _____ 17# _____ LR # _____

REMARKS _____



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	
P/S Pipeline Lead - White Existing Main	<u>E</u>	