

ATION 2001 GASTON DAY SCHOOL Rd. CITY GASTON  
VEEN UNION Rd. STREET & WINCHESTER STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
N TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>196'</u>	<u>6-1-2000</u>		
N TO PROP. LINE	<u>0</u>	<u>0</u>	<u>0</u>			
P LINE TO BLDG.	<u>0</u>	<u>0</u>	<u>196'</u>			


ERS: GASTON DAY SCHOOL GYM BRANCHED INTO:  
SIZE: 3/16" PRESSURE 60 PSI \_\_\_\_\_ INCHES W C LOCATION W. side of gym

PSURE TEST @ 100 PSI FOR 1/4 HRS. BY GK  
N-SIZE 2" C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL \_\_\_\_\_ PLASTIC ✓ YEAR INSTALLED 2006

TH: 3 FT IN LOCATION N. side of gym

P/S READING N/A TOTAL ANODES 1# \_\_\_\_\_ 17# \_\_\_\_\_ L.R. # \_\_\_\_\_

MARKS:  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	
P/S Pipeline Lead - White Existing Main	<u>E</u>	