

LOCATION 4325 Gelinda Ct. CITY Gastonia

BETWEEN Firmin Ct. STREET & Put-de-Sac STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4"	P	87'	11-15-96		
MAIN TO PROP LINE	3/4"	P	30			
PROP. LINE TO BLDG.	3/4"	P	57'			

ENTERS: 4325 BRANCHED INTO:

TAP SIZE: 1/2 PRESSURE 60 PSI INCHES W C LOCATION 603' N.W. of center of

Firmin Ct


PRESSURE TEST: @ 100 PSI FOR 44 HRS. BY S. Huffstut

MAIN-SIZE 2" C.I. BARE STEEL COATED STEEL PLASTIC ☒ YEAR INSTALLED 1996

DEPTH: 3 FT. 0 IN LOCATION 12' NE of center of Gelinda Ct

"A" P/S READING P TOTAL ANODES 1# 0 17# 0 L.R. # 666210

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY