

LOCATION 810 Gibbons St. CITY East.

BETWEEN Parrison Blvd STREET & Light Ave STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>71'</u>			<u>3-25-97</u>
MAIN TO PROP. LINE	<u>"</u>	<u>"</u>	<u>33'</u>			
PROP. LINE TO BLDG.	<u>"</u>	<u>"</u>	<u>38'</u>			

ENTERS: SAME BRANCHED INTO:

TAP SIZE: 3/4" PRESSURE 60 PSI \_\_\_\_\_ INCHES W C LOCATION 107' From @ of

Parrison Blvd


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS BY D.H.J.

MAIN-SIZE 2" C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL \_\_\_\_\_ PLASTIC ✓ YEAR INSTALLED 1997

DEPTH: 3 FT. 0 IN LOCATION Westside of Gibbons St.

"A" P/S READING P TOTAL ANODES 1# - 17# - L.R. # -

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<b>S</b>	
P/S Pipeline Lead - White Existing Main	<b>E</b>	

ENG. DEPT. USE ONLY