

LOCATION 814 GIBBONS ST. CITY Cast.
BETWEEN GARRISON BLVD STREET & Eight Ave. STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P.</u>	<u>71'</u>			<u>3-25-97</u>
MAIN TO PROP. LINE	<u>"</u>	<u>"</u>	<u>28'</u>			
PROP. LINE TO BLDG.	<u>"</u>	<u>"</u>	<u>43'</u>			

ENTERS: SAME BRANCHED INTO:
TAP SIZE: 3/4" PRESSURE 60 PSI _____ INCHES W.C. LOCATION 180' From ⓐ OF
GARRISON BLVD

PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY D.H.F.
MAIN-SIZE 2" C I _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ✓ YEAR INSTALLED 1997
DEPTH: 3 FT. 1 IN LOCATION _____

"A" P/S READING P. TOTAL ANODES 1# - 17# - L.R. # -

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY