

LOCATION 82 Gilman St CITY Gastonia
BETWEEN Chde STREET & Wood STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>Plastic</u>	<u>2'</u>	<u>Tie-over 38' of 3/4 Plastic Service</u>		
MAIN TO PROP. LINE				<u>to 2nd Plastic main</u>		
PROP. LINE TO BLDG.					<u>3-30-98</u>	

ENTERS: 82 BRANCHED INTO: —
TAP SIZE: 3/4 PRESSURE 60 PSI _____ INCHES W C LOCATION _____

PRESSURE TEST: @ 100 PSI FOR 1/4 HRS BY SE
MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 1998
DEPTH: 3 FT. 8 IN. LOCATION _____

"A" P/S READING Plastic TOTAL ANODES 1# _____ 17# _____ L.R. # _____

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>Riser</u>	<u>Plastic</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY