

LOCATION 4627 Glasgow Ct. CITY SAVANNAH
 BETWEEN Abbotts Ford Ct. STREET & End of Cuddeback STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>3/4</u>	<u>Plastic</u>	<u>75'</u>	<u>1-14-00</u>		
MAIN TO PROP LINE	<u>3/4</u>	<u>Plastic</u>	<u>10'</u>			
PROP LINE TO BLDG	<u>3/4</u>	<u>Plastic</u>	<u>65'</u>			

ENTERS 4627 BRANCHED INTO 0
 TAP SIZE 1/2 PRESSURE 60 PSI _____ INCHES WC LOCATION 332' W of Cap of Abbotts Ford Ct.


PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY RL

MAIN SIZE 2" C I _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 1996

DEPTH 3 FT 0 IN LOCATION 18' S of Cap of Glasgow Ct.

"A" P/S READING Plastic N/A TOTAL ANODES 1# 0 17# 0 LR # _____

REMARKS



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead Red New Service	<u>S</u>	<u>0.00</u>
P/S Pipeline Lead White Existing Main	<u>E</u>	<u>0.00</u>

Plastic