


LOCATION 4634 GLASGOWCITY GastoniaBETWEEN Abbotsford LnSTREET & Dead End

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>101</u>	<u>12-9-97</u>		
MAIN TO PROP. LINE	<u>"</u>	<u>"</u>	<u>43</u>			
PROP. LINE TO BLDG.	<u>"</u>	<u>"</u>	<u>58</u>			

ENTERS: 4634BRANCHED INTO: -TAP SIZE: 1/2 PRESSURE \_\_\_\_\_ PSI \_\_\_\_\_ INCHES W.C. LOCATION 17' E. of C ofGLASGOWPRESSURE TEST: @ 100 PSI FOR 1/4 HRS BY EPMAIN-SIZE 2" C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL \_\_\_\_\_ PLASTIC ✓ YEAR INSTALLED 1997DEPTH: 3 FT 0 IN. LOCATION"A" P/S READING P TOTAL ANODES 1# \_\_\_\_\_ 17# \_\_\_\_\_ L.R. # \_\_\_\_\_

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>ER</u>	<u>P</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY