

LOCATION 4635 Glasgow CT CITY Gastonia

BETWEEN Abbotsford CT STREET & Cul-de-Sac STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3 1/4"</u>	<u>P</u>	<u>72'</u>	<u>5-21-98</u>		
MAIN TO PROP. LINE	<u>3 1/4"</u>	<u>P</u>	<u>10'</u>			
PROP. LINE TO BLDG.	<u>3 1/4"</u>	<u>P</u>	<u>62'</u>			

ENTERS: 4635 BRANCHED INTO:

TAP SIZE: 3 1/4" PRESSURE 60 PSI _____ INCHES W.C. LOCATION 254' W. of center of

Abbotsford CT


PRESSURE TEST @ 100 PSI FOR 1 1/4 HRS. BY S. Harkstetter

MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 1997

DEPTH: 3 FT 0 IN LOCATION 12' S. of center of Glasgow CT

"A" P/S READING P TOTAL ANODES 1# 0 17# 0 L.R. # 349046

REMARKS



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY