

LOCATION 700 N. GLENN ST. CITY EAST  
BETWEEN WARE STREET & ESSEX STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>68'</u>		<u>9-17</u>	<u>-96</u>
MAIN TO PROP. LINE	<u>1"</u>	<u>"</u>	<u>5'</u>			
PROP. LINE TO BLDG.	<u>"</u>	<u>"</u>	<u>63'</u>			

ENTERS: 700 BRANCHED INTO:  
TAP SIZE: 3/4" PRESSURE 100 PSI \_\_\_\_\_ INCHES W.C. LOCATION S. of 700

PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY GK  
MAIN-SIZE 2" C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL \_\_\_\_\_ PLASTIC ✓ YEAR INSTALLED 96  
DEPTH: 3 FT. IN. LOCATION E. of N. GLENN

"A" P/S READING P TOTAL ANODES 1# \_\_\_\_\_ 17# \_\_\_\_\_ L.R. # \_\_\_\_\_

REMARKS:  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>P</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY