

LOCATION 701 & 707 N. GlennCITY Castroville

BETWEEN

Essex

STREET &amp;

Ward

STREET

	SIZE	TYPE	701 LENGTH	707	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>85</u>	<u>32</u>		<u>701 N. GLENN</u> <u>85' of 1" BARE</u>	
MAIN TO PROP. LINE	<u>3/4</u>	<u>P</u>	<u>30</u>	<u>10</u>			<u>6-2-94</u>
PROP. LINE TO BLDG.	<u>3/4</u>	<u>P</u>	<u>55</u>	<u>22</u>		<u>707 N. GLENN</u> <u>32' of 1" BARE</u>	

ENTERS: 701BRANCHED INTO: 707TAP SIZE: 1" Ser.

PRESSURE

20

P.S.I.

INCHES W.C.

LOCATION

PRESSURE TEST: @

100

psi

For

1/4

Hrs.

By

EPMAIN-SIZE 2"C.I.   BARE STEEL   COATED STEEL   PLASTIC   

YEAR INSTALLED

1988

DEPTH:

3

Ft.

6


In.

LOCATION

"A" P/S READING

15TOTAL ANODES 1#   17#   L.R. #   

REMARKS:



Test Station

ENG. DEPT. USE ONLY

Reading &amp; Location

Lead

Volts

P/S Pipeline Lead - Red  
New Service

S

P/S Pipeline Lead - White  
Existing Main

E