

LOCATION 722 N GLENN StCITY GASTONIABETWEEN ESSEXSTREET & WARE

STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>67'</u>		<u>6-9-94</u>	<u>6-9-94</u>
MAIN TO PROP. LINE	<u>3/4</u>	<u>P</u>	<u>15'</u>		<u>70' 1" BARE</u>	
PROP. LINE TO BLDG.	<u>3/4</u>	<u>P</u>	<u>52'</u>			

ENTERS: 722

BRANCHED INTO:

TAP SIZE: 1"PRESSURE 60 P.S.I.        INCHES W.C.LOCATION 12' E OF N GLENNPRESSURE TEST: @ 100 psi For 1/4 Hrs. By M. ParkerMAIN-SIZE 2" C.I.        BARE STEEL ✓ COATED STEEL        PLASTIC        YEAR INSTALLED 1956DEPTH: 2 Ft. 0 In. LOCATION 177' South of Essex"A" P/S READING 0.4 TOTAL ANODES 1\* 17 \* 1 L.R. #       

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>P-Riser</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY