

LOCATION 728 + 734 Glenn ST.CITY GASTONIABETWEEN WareSTREET & Essex

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>Plastic</u>	<u>79' + 20' Existing</u>	<u>Tie-over to New</u>		<u>2" Plastic</u>
MAIN TO PROP. LINE				<u>w/ 1' 3/4 Plastic</u>		<u>11-23-96</u>
PROP. LINE TO BLDG.						

ENTERS: 728BRANCHED INTO: 734TAP SIZE: 1/2

PRESSURE

60

P.S.I.

INCHES W.C.

LOCATION

80 South ofEssexPRESSURE TEST: @ 100 psi For 1/4 Hrs. By R HayesMAIN-SIZE 2C.I. BARE STEEL COATED STEEL PLASTIC ✓

YEAR INSTALLED

1996


DEPTH:

3

Ft.

In.

LOCATION

16 East of Glenn"A" P/S READING TOTAL ANODES 1# 17# L.R. # REMARKS: Tie-over Existing 79' + 20' 3/4 Plastic to 2" Plastic
MAIN

Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY