

LOCATION 825 N. Glenn St CITY Gast.

BETWEEN Glenn STREET & Apple Blossom Circle STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>100'</u>		<u>9-18-96</u>	
MAIN TO PROP. LINE	<u>1</u>	<u>"</u>	<u>0</u>			
PROP. LINE TO BLDG.	<u>"</u>	<u>"</u>	<u>100'</u>			

ENTERS: 1112 ESSEX BRANCHED INTO: 825 Glenn

TAP SIZE: 3/4" PRESSURE 100 PSI _____ INCHES W.C. LOCATION S. of 825 Glenn
E. of 1112 ESSEX


PRESSURE TEST: @ 100 PSI FOR 1 1/4 HRS. BY GK

MAIN SIZE 3/4" P. SERV C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ✓ YEAR INSTALLED 96

DEPTH: 1 FT. 6 IN. LOCATION E. of 1112 ESSEX

"A" P/S READING P TOTAL ANODES 1# _____ 17# _____ L.R. # _____

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>P</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY