

LOCATION 2208 GlenRaven Ave CITY GASTONIA
BETWEEN Richland STREET & DAVIS PARK Rd STREET


| | SIZE | TYPE | LENGTH | INSTALLED | RETIRED | RENEWED |
|---------------------|-------------|----------------|-------------|----------------|---------|---------|
| MAIN TO BLDG. | <u>3/4"</u> | <u>Plastic</u> | <u>110'</u> | <u>10/9/95</u> | | |
| MAIN TO PROP. LINE | <u>3/4"</u> | | <u>35'</u> | | | |
| PROP. LINE TO BLDG. | <u>3/4"</u> | | <u>25'</u> | | | |

ENTERS: 2208 BRANCHED INTO:
TAP SIZE: 3/8" PRESSURE 60 P.S.I. _____ INCHES W.C. LOCATION EAST side of 2208

PRESSURE TEST: @ 100 psi For 1/4 Hrs. By DT
MAIN-SIZE 2' C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC _____ YEAR INSTALLED 1969
DEPTH: 2 Ft. 6 In. LOCATION South side of GlenHaven Ave

"A" P/S READING 9.0 TOTAL ANODES 1*0 17*0 L.R. # 501375

REMARKS:



| Test Station | | |
|--|------|-------|
| Reading & Location | Lead | Volts |
| P/S Pipeline Lead - Red New Service | S | |
| P/S Pipeline Lead - White Existing Main | E | |

ENG. DEPT. USE ONLY