

LOCATION 2410 Glenn Ridge Dr. CITY GASTONIA
BETWEEN George Mont Ct. STREET & Saddlewood Dr. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>Plastic</u>	<u>105'</u>	<u>2-18-97</u>		
MAIN TO PROP LINE	<u>3/4</u>	<u>Plastic</u>	<u>40'</u>			
PROP. LINE TO BLDG.	<u>3/4</u>	<u>Plastic</u>	<u>65'</u>			

ENTERS: 2410 BRANCHED INTO: 0
TAP SIZE: 1/2 PRESSURE 60 PSI _____ INCHES W.C. LOCATION 201' S of C of Georgemont Ct


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS BY RL

MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ✓ YEAR INSTALLED 1995

DEPTH: 3 FT. 0 IN. LOCATION 18' w of C of Glenn Ridge Dr.

"A" P/S READING Plastic N/A TOTAL ANODES 1# 0 17# 0 L.R. # 073660

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>Riser</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	<u>Plastic</u>

ENG. DEPT. USE ONLY