

LOCATION 2418 Glenridge DR CITY GASTON, VA
BETWEEN Saddlewood Dr. STREET & Georgetown Dr. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4"	P	113'	8-30-96		
MAIN TO PROP. LINE	3/4"	P	40'			
PROP. LINE TO BLDG.	3/4"	P	73'			

ENTERS: 2418 BRANCHED INTO:
TAP SIZE: 1/2 PRESSURE 60 P.S.I. INCHES W.C. LOCATION 96' S. of center of
Georgetown Dr


PRESSURE TEST: @ 100 psi For 44 Hrs. By S. Chris LeFeltz

MAIN-SIZE 2" C.I. BARE STEEL COATED STEEL PLASTIC ✓ YEAR INSTALLED 1995

DEPTH: 3 Ft. 0 In. LOCATION 20' W. of center of Glenridge DR

"A" P/S READING P TOTAL ANODES 1* 0 17* 0 L.R. # 472359

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY