

LOCATION 2427^{0K} Glen Ridge Dr. CITY GASTONIA
BETWEEN George Mont Dr. STREET & STREET

| | SIZE | TYPE | LENGTH | INSTALLED | RETIRED | RENEWED |
|---------------------|------------|----------------|------------|----------------|---------|---------|
| MAIN TO BLDG. | <u>3/4</u> | <u>Plastic</u> | <u>75'</u> | <u>4-17-96</u> | | |
| MAIN TO PROP. LINE | <u>3/4</u> | <u>Plastic</u> | <u>10'</u> | | | |
| PROP. LINE TO BLDG. | <u>3/4</u> | <u>Plastic</u> | <u>65'</u> | | | |

ENTERS: 2427

BRANCHED INTO: 0

TAP SIZE: 1/2 PRESSURE 60 PSI _____ INCHES W.C. LOCATION 80' N of C of Georgemont Dr.


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY RL

MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ✓ YEAR INSTALLED 1995

DEPTH: 3 FT. 0 IN. LOCATION 20' W of C of Glen Ridge Dr.

"A" P/S READING Plastic N/A TOTAL ANODES 1# 0 17# 0 L.R. # 179606

REMARKS:

|  | Test Station | | | ENG. DEPT. USE ONLY |
|---|--|----------|----------------------|---------------------|
| | Reading & location | Lead | Volts | |
| | P/S Pipeline Lead - Red New Service | <u>S</u> | <u>Riser plastic</u> | |
| | P/S Pipeline Lead - White Existing Main | <u>E</u> | | |