

LOCATION 2459 Glenridge Dr. CITY Cashburn

BETWEEN Georgetown Ct. STREET & Brookwood Dr. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>77'</u>	<u>6-3-97</u>		
MAIN TO PROP. LINE	<u>3/4"</u>	<u>P</u>	<u>5'</u>			
PROP. LINE TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>70'</u>			

ENTERS: 2459 BRANCHED INTO:

TAP SIZE: 1/2 PRESSURE 60 PSI _____ INCHES W.C. LOCATION 70' S. of center of Brookwood Dr.


PRESSURE TEST. @ 100 PSI FOR 1/4 HRS. BY S. Huffstetter

MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 1995

DEPTH: 3 FT. 0 IN. LOCATION 18' W. of center of Glenridge Dr.

"A" P/S READING P TOTAL ANODES 1# 0 17# 0 L.R. # 336658

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY