

LOCATION

2466⁰¹ Glennridge Dr.

CITY

Gastonia

BETWEEN

Brookwood Dr.

STREET &

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4"	P	208'	12-6-95		
MAIN TO PROP. LINE	3/4"	P	45'			
PROP. LINE TO BLDG.	3/4"	P	163'			

ENTERS:

2466

BRANCHED INTO:

TAP SIZE:

1/2

PRESSURE

60

P.S.I.

INCHES W.C.

LOCATION

144' N. of center of
Brookwood Dr.

PRESSURE TEST: @

60

psi

For

1/4

Hrs.

By

S. Huffstetler

MAIN-SIZE 2"

C.I.

BARE STEEL

COATED STEEL

PLASTIC

YEAR INSTALLED

1995

DEPTH:

3 Ft.

0 In.

LOCATION

17' W. of center of Glennridge Dr.

"A" P/S READING

P

TOTAL ANODES 1*

0


17*

0

L.R. #

620520

REMARKS:



Test Station

ENG. DEPT. USE ONLY

Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	