

LOCATION 2475 Glen Ridge Dr. CITY Easton, PA
BETWEEN Sandlewood Dr. STREET & Georgetown Ct. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	3/4"	P	102'	7-10-01		
MAIN TO PROP LINE	3/4"	P	8'	"		
PROP LINE TO BLDG	3/4"	P	94'	"		

ENTERS 2475 BRANCHED INTO 0
TAP SIZE 1/2" PRESSURE 60 PSI _____ INCHES W C LOCATION 144' north


PRESSURE TEST @ 100 PSI FOR 1/2 HRS BY D. Woody of center of Greylyn Ct.

MAIN-SIZE 2" C I _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ✓ YEAR INSTALLED 1995

DEPTH 3' FT 0" IN LOCATION 20' West of center of Glen Ridge Dr.

"A" P/S READING N/A TOTAL ANODES 1# 0 17# 0 L R # A0555562

REMARKS new 3/4" plastic service



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	Plastic
P/S Pipeline Lead - White Existing Main	E	rise