

LOCATION 3024 Goble ST CITY GASTON, N.C.

BETWEEN HUFFMAN ST STREET & MIDWAY ST STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>3/4"</u>	<u>P</u>	<u>90'</u>	<u>7-12-99</u>		
MAIN TO PROP LINE	<u>3/4"</u>	<u>P</u>	<u>30'</u>			
PROP LINE TO BLDG	<u>3/4"</u>	<u>P</u>	<u>60'</u>			

ENTERS 3024 BRANCHED INTO

TAP SIZE 1/2 PRESSURE 40 PSI INCHES W C LOCATION 749' N. of center of Huffman St


PRESSURE TEST @ 100 PSI FOR 4 HRS BY S.G.

MAIN SIZE 2" C I        BARE STEEL        COATED STEEL        PLASTIC ✓ YEAR INSTALLED 1999

DEPTH 3 FT 0 IN LOCATION 13' W. of center of Goble St

"A" P/S READING P TOTAL ANODES 1# 0 17# 0 L.R. # 555805

REMARKS



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead Red New Service	S	
P/S Pipeline Lead White Existing Main	W	